

Certificate of Conformity

By the product certificate number:

No. 2622/0463-B-CER

Issued to:

License holder:

AISWEI Technology (Shanghai) Co., Ltd.
Room 905B, 757 Mengzi Road, Huangpu District,
200023 Shanghai, P.R. China

Trademark:



Manufacturer:

AISWEI New Energy Technology (YangZhong) Co., Ltd.
No. 588 Gangxing Road, Yangzhong, Zhenjiang, China

It is certified that the product:

Type of generating unit: Hybrid Inverter

Models: ASW3000H-S2 / ASW3680H-S2 / ASW4000H-S2 / ASW5000H-S2 / ASW6000H-S2

Technical Data:	Nominal power [W]	See page 2
	Nominal voltage [V]	230
	Nominal frequency [Hz]	50 / 60
	Firmware version	See page 2
	Number of phases	Single Phase
	Isolation Transformer	No

Is in compliance with the standard:

- IEC 61683:1999. "Photovoltaic systems. Power conditioners. Procedure for measuring efficiency".

This certificate is based upon the test results of the Test Report GZES220901844702.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-33 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 4th November 2022

This certificate is valid until 4th November 2027

Madrid, 4th November 2022


Daniel Arranz Muñoz
Certification Manager


Full list of product references and nominal characteristics:

Product Model	ASW3000H-S2	ASW3680H-S2	ASW4000H-S2	ASW5000H-S2	ASW6000H-S2
Input (DC)					
Max.DC Voltage (V)	550				
MPPT Voltage Range (V)	40 ~ 530				
MPPT Full load voltage range (V)	155 ~ 500	155 ~ 500	195 ~ 500	210 ~ 500	210 ~ 500
Max. input current (A)	2*16				
Battery input					
Voltage range (V)	40 ~ 60				
Rated Voltage (V)	48				
Max. Charge/Discharge Power (W)	5000 W / 5000 W				
Max. Charge/Discharge Current (A)	100 A / 100 A				
Output (AC)					
Rated active power (W)	3000	3680	4000	5000	6000
Max. apparent AC power (VA)	3000	3680	4000	5000	6000
Max. Output Current (A)	13.6	16	18.2	22.7	27.3
Nominal Grid Voltage (V)	230				
Nominal Frequency (Hz)	50 / 60				
General Data					
Firmware version for 50 Hz	Master Firmware version: V610-02003-01 Slave Firmware version: V610-60009-00 Safety Firmware version: V610-10008-03				
Firmware version for 60 Hz	Master Firmware version: V610-02003-03 Slave Firmware version: V610-60009-00 Safety Firmware version: V610-10008-05				



Summary efficiency results measured for the tested models:

These efficiency results are representatives for the referred models with a testing frequency of 50Hz.

Power conditioner type – Grid Connected

ASW3000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	95.9%	96.1%	96.2%	96.0%
Nominal input voltage ⁽²⁾	96.8%	97.4%	97.8%	97.6%	97.3%
90% of the maximum rated input voltage ⁽³⁾	95.7%	96.9%	97.2%	97.1%	96.8%

⁽¹⁾ 155 V; ⁽²⁾ 380 V; ⁽³⁾ 495 V

ASW3680H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	95.9%	96.0%	96.0%	95.8%
Nominal input voltage ⁽²⁾	96.3%	97.9%	97.3%	97.1%	96.7%
90% of the maximum rated input voltage ⁽³⁾	96.3%	97.7%	97.2%	96.8%	96.4%

⁽¹⁾ 155 V; ⁽²⁾ 380 V; ⁽³⁾ 495 V

ASW4000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	95.9%	96.2%	95.9%	95.7%
Nominal input voltage ⁽²⁾	96.2%	97.7%	97.6%	97.3%	97.2%
90% of the maximum rated input voltage ⁽³⁾	95.8%	97.2%	97.2%	97.1%	96.7%

⁽¹⁾ 195 V; ⁽²⁾ 380 V; ⁽³⁾ 495 V

ASW5000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	96.3%	96.1%	95.8%	95.5%
Nominal input voltage ⁽²⁾	96.6%	97.9%	97.6%	97.2%	97.0%
90% of the maximum rated input voltage ⁽³⁾	96.6%	97.6%	97.4%	97.1%	96.7%

⁽¹⁾ 210 V; ⁽²⁾ 380 V; ⁽³⁾ 495 V

ASW6000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	96.3%	95.9%	95.7%	95.3%
Nominal input voltage ⁽²⁾	96.5%	97.7%	97.4%	97.1%	96.7%
90% of the maximum rated input voltage ⁽³⁾	96.2%	97.6%	97.1%	96.9%	96.4%

⁽¹⁾ 210 V; ⁽²⁾ 380 V; ⁽³⁾ 495 V



These efficiency results are representatives for the referred models with a testing frequency of 60Hz.

Power conditioner type – Grid Connected

ASW3000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	95.8%	96.2%	96.3%	95.7%
Nominal input voltage ⁽²⁾	96.3%	97.2%	97.8%	97.5%	97.2%
90% of the maximum rated input voltage ⁽³⁾	95.7%	97.2%	97.3%	97.1%	96.9%

⁽¹⁾ 155 V; ⁽²⁾380 V; ⁽³⁾495 V

ASW3680H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	93.9%	95.9%	96.1%	95.9%	95.8%
Nominal input voltage ⁽²⁾	96.3%	97.5%	97.6%	97.4%	97.2%
90% of the maximum rated input voltage ⁽³⁾	95.7%	97.5%	97.4%	97.1%	97.1%

⁽¹⁾ 155 V; ⁽²⁾380 V; ⁽³⁾495 V

ASW4000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	93.9%	96.2%	96.2%	96.1%	96.0%
Nominal input voltage ⁽²⁾	96.2%	97.7%	97.6%	97.5%	97.3%
90% of the maximum rated input voltage ⁽³⁾	96.2%	97.6%	97.2%	96.1%	96.9%

⁽¹⁾ 195 V; ⁽²⁾380 V; ⁽³⁾495 V

ASW5000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.4%	96.0%	96.0%	96.0%	95.6%
Nominal input voltage ⁽²⁾	97.7%	97.7%	97.2%	97.1%	97.0%
90% of the maximum rated input voltage ⁽³⁾	96.6%	97.6%	97.4%	97.1%	96.8%

⁽¹⁾ 155 V; ⁽²⁾380 V; ⁽³⁾495 V

ASW6000H-S2					
Test condition	10%Sn	25%Sn	50%Sn	75%Sn	100%Sn
Minimum rated input voltage ⁽¹⁾	94.7%	96.2%	94.6%	95.7%	95.4%
Nominal input voltage ⁽²⁾	97.8%	96.7%	97.6%	97.0%	96.7%
90% of the maximum rated input voltage ⁽³⁾	96.5%	97.7%	97.4%	96.9%	96.4%

⁽¹⁾ 155 V; ⁽²⁾380 V; ⁽³⁾495 V

