

Compliance Document

No. D 099567 0073 Rev. 00


Holder of Certificate: **AISWEI Technology (Shanghai) Co., Ltd.**
Room 905B, 757 Mengzi Road
Huangpu District
200023 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
Grid-connected Hybrid Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092228620-00

Date, 2022-08-31


(Zhengdong Ma)

Compliance Document

No. D 099567 0073 Rev. 00

Model(s): ASW3680H-S2, ASW3000H-S2

Parameters:

	ASW3680H-S2	ASW3000H-S2
a) PV input:		
Max. PV input voltage	550 V d.c.	
MPP voltage range	40-530 V d.c.	
Max. PV input current	2*16 A d.c.	
Isc PV (absolute maximum)	2*20 A d.c.	
b) Grid output:		
Rated grid voltage	230 V a.c.	
Rated grid frequency	50 Hz	
Rated grid output acitve power	3680 W	3000 W
Rated grid output apparent power	3680 VA	3000 VA
Max. grid output apparent power	3680 VA	3000 VA
Max. grid output current	16 A a.c.	13.6 A a.c.
Adjustable cos(φ)	0.8 ind ... 0.8 cap	

**Tested
according to:**

G98/1-5:2021